

605 # 2

Location
Shed, 100TH
Se
PV

MARKED

7-26-84

RADIATOR Repaired Dec 1986 (Leaked)

ALTERNATOR Repaired Dec 1986

- new Brgs, Brushes, -

New cap, electronic ignition module

May 3, 87

July-88 - New output Bearings - rear seal

New idler Bearing

Dec-88 - New heads -

Air Filter

FAN Belts, Alternator - Brushes - BEARING Front & Back

Hour meter Reads 5281 (5796)

Fall 89 - Hour meter reads 6262 Hrs.

New cap & rotor

July 90 New Hr meter 511 Hrs. start

End old Hr meter 6823 ? - finish

Aug 90 - Heads - valley gaskets 872 Hrs.

Alt. Brushed Bearing Plugs & Cap Rotor

Yr. End 1990 - meter 6823 Hrs.

July 10-1991 1577 Hrs. - New air filter - Alt. belt.

New Hr meter start 977 Hrs. Frt. Alt. brg.

1991 Yr. end meter 2334 Hrs. (1367 for Yr.)

- New exhaust Manifolds -

92 Yr end - meter 3113 Hrs

4-95 - Alt. Bearing

Yr end 98 - 3727 Hrs

Comp - 7-10-02

100 130 135 135

110 115 110 110

02 Yr end - +02

8704 Hrs

New Heads - Radiator -

7-21-04 removed low comp

55 45 45 45

85 65 90 85

Walt H

Hr Meter 8402 - (removed meter)

Lot # 77